



NATURAL GAS LIGHTING REQUIREMENTS

COMMUNITY DEVELOPMENT DEPARTMENT

1400 Highland Avenue, Manhattan Beach, CA 90266-4795

Telephone (310) 802-5544

Website: www.manhattanbeach.gov

The following is the procedure regulating the installation of Residential Natural Gas Light Fixtures. Jobs in progress must adhere as close as possible depending on the work completed. Under all circumstances, the fixtures must be on the approved plans, the fixtures must be listed and installed per code.

- Natural gas light fixtures shall be listed by CSA, UL, ASTM or other recognized organization.
- The location of the fixtures shall be on the approved plans.
- The fixtures must be approved by the building inspector at the time of rough gas inspection and again at final inspection
- All fittings located within the building cavity must be approved for concealed locations (CPC 1210.3)
- A gas shutoff shall be readily accessible and located within six feet of the fixture. (CPC 1212.6)
- Installation of gas line for future fixtures is not allowed. If installed, the pipping shall be removed and the tee or other branch fitting, if present, shall be replaced.